NC/QC/YPD-W-4/2018-19/AL-CB9 **Date: 08-03-2019**

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).
{Project*: Improvements to roads and drains at Ambedkar nagara, LBS nagara and Allalasandra in Ward no. 04 of Yelahanka New Town).}
Ref.: Material testing/PMC/18-19,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.
Name of the Agency/Contractor*: Sri. Venkategowda. G, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	01-03-19	08-03-19	07	22500	355	15.78	**16.07**
	002	‘’	“	‘’	“	360	16.00	
	003	‘’	“	‘’	“	370	16.44	

KIRAN. R
M.E, (Civil-Engg)

Page No. 1/1,

Asst. Executive Engr.
Project Division
Yelahanka Zone
Bangalore

For Newzen Consultants Bangalore

Proprietor

NC/QC/YPD-W-4/2018-19/AL-CB10 **Date: 08-03-2019**

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).
{Project*: Improvements to roads and drains at Ambedkar nagara, LBS nagara and Allalasandra in Ward no. 04 of Yelahanka New Town).}
Ref.: Material testing/PMC/18-19,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.
Name of the Agency/Contractor*: Sri. Venkategowda. G, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	01-03-19	08-03-19	07	22500	365	16.22	**16.44**
	002	"	"	"	"	375	16.67	
	003	"	"	"	"	370	16.44	

K.R
KIRAN
M.E. (Civil-Engg)

Page No. 1/1,

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

For Newzen Consultants Bangalore

Proprietor

NC/QC/YPD-W-4/2018-19/AL-CB11 **Date: 08-03-2019**

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).
{Project*: Improvements to roads and drains at Ambedkar nagara, LBS nagara and Allalasandra in Ward no. 04 of Yelahanka New Town).}
Ref.: Material testing/PMC/18-19,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.
Name of the Agency/Contractor*: Sri. Venkategowda. G, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	01-03-19	08-03-19	07	22500	375	16.67	**16.74**
	002	"	"	"	"	385	17.11	
	003	"	"	"	"	370	16.44	

KIRAN. R
M.E, (Civil-Engg)

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

For Newzen Consultants Bangalore

Proprietor

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA, JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL:newzen576@gmail.com

NC/QC/YPD-W-4/2018-19/AL-CB12 **Date: 11-03-2019**

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).
{Project*: Improvements to roads and drains at Ambedkar nagara, LBS nagara and Allalasandra in Ward no. 04 of Yelahanka New Town).}
Ref.: Material testing/PMC/18-19,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.
Name of the Agency/Contractor*: Sri. Venkategowda. G, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	02-03-19	11-03-19	09	22500	385	17.11	**17.04**
	002	"	"	"	"	375	16.67	
	003	"	"	"	"	390	17.33	

KIRAN. R
M.E, (Civil-Engg)

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

For Newzen Consultants Bangalore

Proprietor

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA,
JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL:newzen576@gmail.com

NCQC/YPD-W-4/2018-19/AL-CB13 Date: 11-03-2019

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).
{Project*: Improvements to roads and drains at Ambedkar nagara, LBS nagara and Allalasandra in Ward no. 04 of Yelahanka New Town).}
Ref.: Material testing/PMC/18-19,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.
Name of the Agency/Contractor*: Sri. Venkategowda. G, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	02-03-19	11-03-19	07	22500	375	16.66	**16.66**
	002	"	"	"	"	365	16.22	
	003	"	"	"	"	380	17.11	

KIRAN. R
M.E. (Civil-Engg)

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

For Newzen Consultants Bangalore

Proprietor

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA,
JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL:newzen576@gmail.com

NC/QC/YPD-W-4/2018-19/AL-CB6A

Date: 28-03-2019

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).
{Project*: Improvements to roads and drains at Ambedkar nagara, LBS nagara and Allalasandra in Ward no. 04 of Yelahanka New Town).}
Ref.: Material testing/PMC/18-19,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.
Name of the Agency/Contractor*: Sri. Venkategowda. G, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	28-02-19	28-03-19	28	22500	495	22.00	**22.30**
	002	"	"	"	"	500	22.22	
	003	"	"	"	"	510	22.67	

KIRAN. R
M.E. (Civil-Engg)

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

For Newzen Consultants Bangalore

Proprietor

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA, JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187

NC/QC/YPD-W-4/2018-19/AL-CB7A Date: 28-03-2019

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Improvements to roads and drains at Ambedkar nagara, LBS nagara and Allalasandra in Ward no. 04 of Yelahanka New Town).}

Ref.: Material testing/PMC/18-19,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri. Venkategowda. G, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	28-02-19	28-03-19	28	22500	520	23.11	**23.11**
	002	"	"	"	"	515	22.89	
	003	"	"	"	"	525	23.33	

KIRAN. R
M.E, (Civil-Engg)

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

For Newzen Consultants Bangalore

Proprietor

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA, JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL:newzen576@gmail.com

NC/QC/YPD-W-4/2018-19/AL-CB8A Date: 28-03-2019

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).
{Project*: Improvements to roads and drains at Ambedkar nagara, LBS nagara and Allalasandra in Ward no. 04 of Yelahanka New Town).}
Ref.: Material testing/PMC/18-19,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.
Name of the Agency/Contractor*: Sri. Venkategowda. G, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	28-02-19	28-03-19	28	22500	505	22.44	**22.74**
	002	"	"	"	"	510	22.67	
	003	"	"	"	"	520	23.11	

K. R
KIRAN. R
M.E, (Civil-Engg)

Page No. 1/1,

Project Division
Yelahanka Zone
Bangalore

For Newzen Consultants Bangalore

Proprietor

NC/QC/YPD-W-4/2018-19/AL-CB9A

Date: 29-03-2019

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Improvements to roads and drains at Ambedkar nagara, LBS nagara and Allalasandra in Ward no. 04 of Yelahanka New Town).}

Ref.: Material testing/PMC/18-19,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri. Venkategowda. G, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	01-03-19	29-03-19	28	22500	515	22.89	**22.59**
	002	"	"	"	"	500	22.22	
	003	"	"	"	"	510	22.67	

KIRAN. R
M.E, (Civil-Engg)

Page No. 1/1,

Project Director
Yelahanka Zone
Bangalore

For Newzen Consultants Bangalore

Proprietor

NC/QC/YPD-W-4/2018-19/AL-CB10A **Date: 29-03-2019**

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).
{Project*: Improvements to roads and drains at Ambedkar nagara, LBS nagara and Allalasandra in Ward no. 04 of Yelahanka New Town).}
Ref.: Material testing/PMC/18-19,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.
Name of the Agency/Contractor*: Sri. Venkategowda. G, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	01-03-19	29-03-19	28	22500	530	23.56	**23.41**
	002	"	"	"	"	520	23.11	
	003	"	"	"	"	530	23.56	

K.R
KIRAN. R
M.E, (Civil-Engg)

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

For Newzen Consultants Bangalore

Proprietor

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA, JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL:newzen576@gmail.com

NC/QC/YPD-W-4/2018-19/AL-CB11A

Date: 29-03-2019

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).
{Project*: Improvements to roads and drains at Ambedkar nagara, LBS nagara and Allalasandra in Ward no. 04 of Yelahanka New Town).}
Ref.: Material testing/PMC/18-19,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.
Name of the Agency/Contractor*: Sri. Venkategowda. G, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	01-03-19	29-03-19	28	22500	500	22.22	**22.74**
	002	"	"	"	"	515	22.89	
	003	"	"	"	"	520	23.11	

Page No. 1/1,

K. R
KIRAN. R
M.E, (Civil-Engg)

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

For Newzen Consultants Bangalore

Proprietor

NC/QC/YPD-W-4/2018-19/AL-CB12A

Date: 30-03-2019

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).
{Project*: Improvements to roads and drains at Ambedkar nagara, LBS nagara and Allalasandra in Ward no. 04 of Yelahanka New Town).}
Ref.: Material testing/PMC/18-19,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.
Name of the Agency/Contractor*: Sri. Venkategowda. G, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	02-03-19	30-03-19	28	22500	500	22.22	**23.04**
	002	"	"	"	"	525	23.33	
	003	"	"	"	"	530	23.56	

KIRAN. R
M.E, (Civil-Engg)

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

For Newzen Consultants Bangalore

Proprietor

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA,
JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL:newzen576@gmail.com

NC/QC/YPD-W-4/2018-19/AL-CB13A

Date: 30-03-2019

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).
{Project*: Improvements to roads and drains at Ambedkar nagara, LBS nagara and Allalasandra in Ward no. 04 of Yelahanka New Town).}
Ref.: Material testing/PMC/18-19,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.
Name of the Agency/Contractor*: Sri. Venkategowda. G, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	02-03-19	30-03-19	28	22500	500	22.22	**22.30**
	002	"	"	"	"	510	22.67	
	003	"	"	"	"	495	22.00	

K.R
KIRAN. R
M.E, (Civil-Engg)

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

For Newzen Consultants Bangalore

Proprietor

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA, JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL:newzen576@gmail.com